

**Incident Report - (Incident UID - IMF/MHC/GRA/PD/26/00002)**

**Incident Information**

<b>Incident UID</b>	IMF/MHC/GRA/PD/26/00002	<b>Category Name</b>	Property Damage
<b>Status</b>	FIR Released	<b>Site Name</b>	Leeper
<b>Reported By</b>	Laddie Gaffney	<b>Incident Date &amp; Time</b>	02-Mar-2026 07:15:00 PM
<b>Created On</b>	03-Mar-2026 02:55:59 PM		

**Incident Description**

On 02.03.2026 at around 07:15 PM, during facade glass lifting activity at Tower-10 from UG East Side to Level-35 using a floor crane, the facade glass panel struck the facade pins at Level-31 while being lifted. Due to the impact, the glass panel broke and pieces of glass fell to the UG level. No personnel were injured, property damage occurred due to the breakage of the facade glass panel.

**Sections**

**FIR basic details**

Part of body: [ "Others" ]

<b>Name of the victim</b>	NA
<b>Age of the Victim</b>	NA
<b>Name of the contractor/MH</b>	ALUPLEX
<b>Details of people involved</b>	The facade glass lifting activity was carried out by the Aluplex facade team using a floor crane operator at Tower-10. The activity was supervised by rajender site supervisor and lifting team.
<b>Details of Equipment involved</b>	Floor crane
<b>Involved Activity</b>	Facade glass shifting
<b>Details of reporting person</b>	Srikanth
<b>Emergency physician on site?</b>	NA
<b>Name of the physician</b>	A.S Deshikulu
<b>Peoples injured</b>	NA
<b>Type of injury</b>	NA
	Property damage
<b>Part of body</b>	NA
	NA
<b>(Expected) Day of return to work: (Date or Time)</b>	NA

<b>Attachments</b>
□ □ □

**Immediate corrective action is taken**

S.No.	Actions	Responsible	Target date
1	The lifting activity was immediately stopped after the facade glass panel broke.	Muthuswamy	02-Mar-2026
2	The area at UG level was cordoned off with barricading to prevent entry of unauthorized persons.	Avinash	02-Mar-2026
3	toolbox talk was conducted for the lifting team regarding safe lifting procedures and communication during lifting activities.	Muthuswamy	03-Mar-2026

**Incident History**

Created On	Updated By	Comment	Attachments
04-Mar-2026 11:48:05 AM	Renard Whatley	Incident Status has been updated to 'FIRReleased'	

04-Mar-2026 11:47:55 AM	Renard Whatley	Incident Status has been updated to 'Validated'	
03-Mar-2026 02:56:00 PM	Laddie Gaffney	A new record was created: Site set to 'Grava' Process set to 'NA' Asset set to 'NA' Reported By set to 'A Venkateswara Reddy' Type Of Incident set to 'Property Damage' Incident Description set to 'On 02.03.2026 at around 07:15 PM, during facade glass lifting activity at Tower-10 from UG East Side to Level-35 using a floor crane, the facade glass panel struck the facade pins at Level-31 while being lifted. Due to the impact, the glass panel broke and pieces of glass fell to the UG level.No personnel were injured, property damage occurred due to the breakage of the facade glass panel.' Incident Date Time set to '02-Mar-2026 07:15:00 PM' Status set to 'Submit'	